

---

## **Span tables for solid timber members in floors, ceilings and roofs (excluding trussed rafter roofs) for dwellings**

TRADA Technology Design Aid DA 1/2004

© TRADA Technology Ltd 2004  
Reprinted with amendments March 2005

ISBN 1 900510 46 4



Chiltern House      Stocking Lane  
Hughenden Valley High Wycombe  
Buckinghamshire HP14 4ND UK  
t: +44 (0)1494 569600    f: +44 (0)1494 565487  
w: [www.trada.co.uk](http://www.trada.co.uk)    e: [information@trada.co.uk](mailto:information@trada.co.uk)



Whilst every effort is made to ensure the accuracy of the advice given, the company cannot accept liability for loss or damage arising from the information supplied.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form, by any means, electronic, mechanical, photocopying, recording or otherwise, without the prior permission of the copyright owners.

## Contents

		Page
	<b>Preface</b>	<b>5</b>
	TRADA	6
	TRADA Technology	6
<b>1.0</b>	<b>Introduction</b>	<b>7</b>
<b>2.0</b>	<b>Timber specifications</b>	<b>9</b>
2.1	Timber availability	10
<b>3.0</b>	<b>Design considerations</b>	<b>11</b>
3.1	Loading	11
3.2	Construction and basic workmanship recommendations	12
<b>4.0</b>	<b>Tables of sizes of timber members</b>	<b>13</b>
4.1	Floor joists	15
4.2	Ceiling joists and binders supporting ceiling joists	19
4.3	Rafters and purlins supporting rafters	23
4.4	Flat roof joists	37
4.5	Purlins supporting sheeting or cladding	43
<b>5.0</b>	<b>References</b>	<b>46</b>
<b>Appendix 1</b>		
	Explanatory notes: FAQs	47

## List of Figures

Figure 1	Snow roof loading zones.	11
Figure 2	Key to Tables 6 – 45.	13
Figure 3	Floor joists arrangement.	15
Figure 4	Ceiling joists and binders arrangement.	19
Figure 5	Typical rafters and purlin arrangement.	23
Figure 6	Typical flat roof joists arrangement.	36
Figure 7	Purlins supporting roof sheeting or cladding arrangement.	43

## List of Tables

Table 1	Imposed loads for floors, ceilings and roofs.	7
Table 2	Common species/grade combinations which satisfy the requirements for the strength classes to which Tables 6-45 relate.	9
Table 3	Imposed roof loads for the zones defined in Figure 1.	11
Table 4	Strutting or blocking of joists.	12
Table 5	Summary of Tables 6 – 45.	14
Table 6	Domestic floor joists. C16 timber.	16
Table 7	Domestic floor joists. C24 timber.	17
Table 8	Ceiling joists. C16 timber.	19
Table 9	Ceiling joists. C24 timber.	20
Table 10	Ceiling binders. C16 timber.	21
Table 11	Ceiling binders. C24 timber.	21
Table 12	Common or jack rafters. Roof slope 15° - 22.5°. Imposed load 0.75 kN/m <sup>2</sup> . C16 timber.	24
Table 13	Common or jack rafters. Roof slope 15° - 22.5°. Imposed load 0.75 kN/m <sup>2</sup> . C24 timber.	24
Table 14	Purlins supporting rafters. Roof slope 15° - 22.5°. Imposed load 0.75 kN/m <sup>2</sup> . C16 timber.	25
Table 15	Purlins supporting rafters. Roof slope 15° - 22.5°. Imposed load 0.75 kN/m <sup>2</sup> . C24 timber.	25
Table 16	Common or jack rafters. Roof slope 15° - 22.5°. Imposed load 1.0 kN/m <sup>2</sup> . C16 timber.	26
Table 17	Common or jack rafters. Roof slope 15° - 22.5°. Imposed load 1.0 kN/m <sup>2</sup> . C24 timber.	26
Table 18	Purlins supporting rafters. Roof slope 15° - 22.5°. Imposed load 1.0 kN/m <sup>2</sup> . C16 timber.	27
Table 19	Purlins supporting rafters. Roof slope 15° - 22.5°. Imposed load 1.0 kN/m <sup>2</sup> . C24 timber.	27
Table 20	Common or jack rafters. Roof slope 22.5° - 30°. Imposed load 0.75 kN/m <sup>2</sup> . C16 timber.	28
Table 21	Common or jack rafters. Roof slope 22.5° - 30°. Imposed load 0.75 kN/m <sup>2</sup> . C24 timber.	28
Table 22	Purlins supporting rafters. Roof slope 22.5° - 30°. Imposed load 0.75 kN/m <sup>2</sup> . C16 timber.	29
Table 23	Purlins supporting rafters. Roof slope 22.5° - 30°. Imposed load 0.75 kN/m <sup>2</sup> . C24 timber.	29
Table 24	Common or jack rafters. Roof slope 22.5° - 30°. Imposed load 1.0 kN/m <sup>2</sup> . C16 timber.	30
Table 25	Common or jack rafters. Roof slope 22.5° - 30°. Imposed load 1.0 kN/m <sup>2</sup> . C24 timber.	30
Table 26	Purlins supporting rafters. Roof slope 22.5° - 30°. Imposed load 1.0 kN/m <sup>2</sup> . C16 timber.	31
Table 27	Purlins supporting rafters. Roof slope 22.5° - 30°. Imposed load 1.0 kN/m <sup>2</sup> . C24 timber.	31
Table 28	Common or jack rafters. Roof slope 30° - 45°. Imposed load 0.75 kN/m <sup>2</sup> . C16 timber.	32
Table 29	Common or jack rafters. Roof slope 30° - 45°. Imposed load 0.75 kN/m <sup>2</sup> . C24 timber.	32
Table 30	Purlins supporting rafters. Roof slope 30° - 45°. Imposed load 0.75 kN/m <sup>2</sup> . C16 timber.	33
Table 31	Purlins supporting rafters. Roof slope 30° - 45°. Imposed load 0.75 kN/m <sup>2</sup> . C24 timber.	33
Table 32	Common or jack rafters. Roof slope 30° - 45°. Imposed load 1.0 kN/m <sup>2</sup> . C16 timber.	34
Table 33	Common or jack rafters. Roof slope 30° - 45°. Imposed load 1.0 kN/m <sup>2</sup> . C24 timber.	34
Table 34	Purlins supporting rafters. Roof slope 30° - 45°. Imposed load 1.0 kN/m <sup>2</sup> . C16 timber.	35
Table 35	Purlins supporting rafters. Roof slope 30° - 45°. Imposed load 1.0 kN/m <sup>2</sup> . C24 timber.	35
Table 36	Joists for flat roofs with access for maintenance and repair only. Imposed load 0.75 kN/m <sup>2</sup> . C16 timber.	37
Table 37	Joists for flat roofs with access for maintenance and repair only. Imposed load 0.75 kN/m <sup>2</sup> . C24 timber.	38
Table 38	Joists for flat roofs with access for maintenance and repair only. Imposed load 1.0 kN/m <sup>2</sup> . C16 timber.	39
Table 39	Joists for flat roofs with access for maintenance and repair only. Imposed load 1.0 kN/m <sup>2</sup> . C24 timber.	40
Table 40	Joists for flat roofs with unlimited access. Imposed load 1.5 kN/m <sup>2</sup> . C16 timber.	41
Table 41	Joists for flat roofs with unlimited access. Imposed load 1.5 kN/m <sup>2</sup> . C24 timber.	42
Table 42	Purlins supporting roof sheeting or cladding. Roof slope 10° - 35°. Imposed load 0.75 kN/m <sup>2</sup> . C16 timber.	44
Table 43	Purlins supporting roof sheeting or cladding. Roof slope 10° - 35°. Imposed load 0.75 kN/m <sup>2</sup> . C24 timber.	44
Table 44	Purlins supporting roof sheeting or cladding. Roof slope 10° - 35°. Imposed load 1.0 kN/m <sup>2</sup> . C16 timber.	45
Table 45	Purlins supporting roof sheeting or cladding. Roof slope 10° - 35°. Imposed load 1.0 kN/m <sup>2</sup> . C24 timber.	45